PASS QUESTION

QUESTION & ANSWER

HIGHER QUALITY, BETTER SERVICE

Provide One Year Free Update!

https://www.passquestion.com

Exam : **DCDC-004**

Title : BICSI Data Center Design Consultant (DCDC)

Version : DEMO

1.What room should have its own dedicated air handling system apart from the computer room?
A. Electrical Room
B. Break Room
C. Printer Room
D. Storage Room
E. Telecommunications Room
Answer: C

2.What is the recommended amount of fuel supply needing to be available to a class F2 data center?
A. 12 hours
B. 18 hours
C. 24 hours
D. 30 hours
E. 36 hours
Answer: C

3.What is the minimum size conductor from the TMGB to the building main ground bus?
A. 80mm (150MCM) bare copper
B. 100mm (200MCM) bare copper
C. 130mm (250MCM) bare copper
D. 160mm (300MCM) bare copper
E. 200mm (400MCM) bare copper
Answer: C

4.What is the minimum distance from the bottom of the access floor to the top of the cable tray?
A. 1 inch
B. 2 inches
C. 3 inches
D. 4 inches
E. 5 inches
Answer: B

5.What is the distance from the bottom of the access floor to the bottom of the cable tray?
A. 6 inches
B. 7 inches
C. 8 inches
D. 9 inches
E. 10 inches
Answer: C